

# WELLS RIVER WATER SYSTEM - VT0005176

## Consumer Confidence Report - 2021

This report is a snapshot of the quality of the water that we provided in 2021. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. This report is designed to inform you about the quality water and services we deliver to you every day. To learn more, please attend any of our regularly scheduled meetings which are held:

1<sup>st</sup> and 3<sup>rd</sup> Thursday's 4 PM (date/time) at Village Office (location).

The person who can answer questions about this report is: (print) JEFFREY MORIN

Telephone: 802-757-2706 and/ or Email wrfdk1@charter.net

## Water Source Information

**Your water comes from:**

Source Name	Source Water Type
WELL #1-MAIN WELL	Groundwater

The State of Vermont Water Supply Rule requires Public Community Water Systems to develop a Source Protection Plan. This plan delineates a source protection area for our system and identifies potential and actual sources of contamination. Please contact us if you are interested in reviewing the plan.

## Drinking Water Contaminants

The sources of drinking water (both tap water and bottled water) include surface water (streams, lakes) and ground water (wells, springs). As water travels over the land's surface or through the ground, it dissolves naturally-occurring minerals. It also picks up substances resulting from the presence of animals and human activity. Some "contaminants" may be harmful. Others, such as iron and sulfur, are not harmful. Public water systems treat water to remove contaminants, if any are present.

In order to ensure that your water is safe to drink, we test it regularly according to regulations established by the U.S. Environmental Protection Agency and the State of Vermont. These regulations limit the amount of various contaminants:

**Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife

**Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

**Pesticides and herbicides**, may come from a variety of sources such as storm water run-off, agriculture, and residential users.

**Radioactive contaminants**, which can be naturally occurring or the result of mining activity

**Organic contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

## Water Quality Data

The table below lists all the drinking water contaminants that we detected during the past year. It also includes the date and results of any contaminants that we detected within the past five years if tested less than once a year. The presence of these contaminants in the water does not necessarily show that the water poses a health risk.

**Terms and abbreviations** - In this table you may find terms you might not be familiar with. To help you better understand these terms we have provided the following definitions:

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Level 1 Assessment:** A level 1 Assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 Assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**Locational Running Annual Average (LRAA):** The average of sample analytical results for samples taken at a particular monitoring location during four consecutive calendar quarters.

**Maximum Contamination Level (MCL):** The “Maximum Allowed” MCL is the highest level of a contaminant that is allowed in drinking water. MCL’s are set as close to the MCLG’s as feasible using the best available treatment technology.

**Maximum Contamination Level Goal (MCLG):** The “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLG’s allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. Addition a disinfectant may help control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of disinfectants in controlling microbial contaminants.

**Nephelometric Turbidity Unit (NTU):** NTU is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**Parts per million (ppm) or Milligrams per liter (mg/l):** (one penny in ten thousand dollars)

**Parts per billion (ppb) or Micrograms per liter (ug/l):** (one penny in ten million dollars)

**Parts per trillion (ppt) or Nanograms per liter (ng/l):** (one penny in ten billion dollars)

**Picocuries per liter (pCi/L):** a measure of radioactivity in water

**Running Annual Average (RAA):** The average of 4 consecutive quarters (when on quarterly monitoring); values in table represent the highest RAA for the year.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**90th Percentile:** Ninety percent of the samples are below the action level. (Nine of ten sites sampled were at or below this level).

**Per- and polyfluoroalkyl substances (PFAS):** a group of over 4,000 human-made chemicals (they do not occur naturally) that have been used in industry and consumer products worldwide and includes:

**(PFNA): Perfluorononanoic Acid**

**(PFOA): Perfluorooctanoic Acid**

**(PFOS): Perfluorooctane Sulfonic Acid**

**(PFHpA): Perfluoroheptanoic Acid**

**(PFHxS): Perfluorohexane Sulfonic Acid**

**(11Cl-PF3OUdS): 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid**

**(9Cl-PF3ONS): 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic Acid**

**(DONA): 4,8-Dioxa-3H-perfluorononanoic Acid**

**(HFPO-DA): Hexafluoropropylene Oxide Dimer Acid**  
**(NEtFOSAA): N-ethyl perfluorooctanesulfonamidoacetic Acid**  
**(NMeFOSAA): N-methyl perfluorooctanesulfonamidoacetic Acid**  
**(PFBS): Perfluorobutane Sulfonic Acid**  
**(PFDA): Perfluorodecanoic Acid**  
**(PFDoA): Perfluorododecanoic Acid**  
**(PFHxA): Perfluorohexanoic Acid**  
**(PFTA): Perfluorotetradecanoic Acid**  
**(PFTrDA): Perfluorotridecanoic Acid**  
**(PFUnA): Perfluoroundecanoic Acid**

## Detected Contaminants WELLS RIVER WATER SYSTEM

Disinfection Residual	RAA	RANGE	Unit	MRDL	MRDLG	Typical Source
Chlorine	0.224	0.110 - 0.320	mg/l	4	4	Water additive to control microbes

Chemical Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
Manganese	10/19/2021	130	45 - 130	ppb	NA	NA	Erosion of natural deposits. Vermont Department of Health has established a Health Advisory of 300 ppb. Manganese equal to or greater than 50 ppb can lead to unacceptable taste or staining of fixtures.
Nitrate	02/24/2021	0.087	0.087 - 0.087	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Radionuclides	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
Combined Radium (-226 & -228)	07/16/2019	1.437	1.437 - 1.437	pCi/L	5	0	Erosion of natural deposits
Radium-226	07/16/2019	0.471	0.471 - 0.471	pCi/L	5	0	Erosion of natural deposits
Radium-228	07/16/2019	0.966	0.966 - 0.966	pCi/L	5	0	Erosion of natural deposits

Disinfection ByProducts	Collection Year	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
Total Trihalomethanes	2021	15	15 - 15	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Collection Year	90th Percentile	Range	Unit	AL*	Sites Over AL	Typical Source
-----------------	-----------------	-----------------	-------	------	-----	---------------	----------------

Lead	2021	0	0 - 0	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits
Copper	2021	0.058	0 - 0.058	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

\*The lead and copper AL (Action Level) exceedance is based on the 90th percentile concentration, not the highest detected result.

## Health Information Regarding Drinking Water

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants, can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from EPA's Safe Drinking Water Hotline (1-800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Safe Drinking Water Hotline.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. WELLS RIVER WATER SYSTEM is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## Uncorrected Significant Deficiencies

The system is required to inform the public of any significant deficiencies identified during a sanitary survey conducted by the Drinking Water and Groundwater Protection Division that have not yet been corrected. For more information please refer to the schedule for compliance in the system's Operating Permit.

Date Identified	Significant Deficiencies	Facility
09/17/2019	System Modification without a Construction Permit	
09/17/2019	Inadequate Chemical Application Facilities	TREATMENT PLANT 2
09/17/2019	Monthly Reporting Inadequate	
09/17/2019	System Modification without a Construction Permit	

02/24/2017	Inadequate Water Pressure (Under Normal, Peak, or Maximum Flow Conditions)	DISTRIBUTION SYSTEM
------------	--	---------------------

**To be Completed by the Water System.** *Describe any interim measures taken or work completed for the deficiencies listed above:*

**Public Notice - Permit to Operate Issued:** The Water System is required to notify all users of the following compliance schedule contained in the Permit to Operate issued by the State of Vermont Agency of Natural Resources:

1. **On or before April 1, 2015**, the Permittee shall maintain a minimum of 0.1 mg/L free chlorine to ends of the distribution system. A measurement of the chlorine disinfection residual concentration is to be measured from or near the end of the water distribution system main located at the south end of Tullar Road to verify that a minimum of 0.1 mg/L free chlorine residual concentration is being maintained in the distribution system. The results of the daily disinfectant residual monitoring shall be included on the reporting form that is submitted to the Division each month. Disinfectant residual concentration monitoring shall continue until otherwise directed by the Division.
2. **On or before October 1, 2016**, the Permittee shall complete construction of the replacement water storage tank in accordance with the PTC that has been issued by the Secretary.
3. **On or before October 1, 2016**, the Permittee shall complete construction of the booster pump station on the Bible Hill section of the Water System in accordance with the PTC that has been issued by the Secretary.
4. **On or before October 1, 2016**, the Permitted shall complete all proposed water distribution system improvements, (including the replacement, modification, or elimination of inadequate fire hydrants), in accordance with the PTC that has been issued by the Secretary.
5. **On or before December 1, 2016**, the Permittee shall submit a Capital Improvements Plan (CIP) and schedule for any remaining distribution system piping improvements that are necessary to comply with Appendix A, technical standards, as specified by the Rule.

**To be completed by the Water System:**

*Describe any interim measures completed or progress to date for the compliance schedule(s) listed above.*

1. Currently monitoring.
2. Complete and waiting for an amended Operating Permit.
3. Working with the Water Division on a resolution for this issue.
4. Complete and waiting for an amended Operating Permit from the Water Division.
5. This is still something that needs to be done.

**Distribution Information**

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place and distributing copies by hand or mail.*

**Per- and Polyfluoroalkyl Substances (PFAS) are contaminants you may see reported in your Consumer Confidence Report (CCR) for the first time.**

### **What are PFAS?**

PFAS are a group of over 4,000 human-made chemicals (they do not occur naturally) that have been used in industry and consumer products worldwide since at least the 1950s. These chemicals are used to make household and commercial products that resist heat and chemical reactions and repel oil, stains, grease, and water. Some common products that may contain PFAS include non-stick cookware, water-resistant clothing and materials, cleaning products, cosmetics, food packaging materials, and some personal care products. Due to their resilient chemical nature, they don't readily degrade once they are released into the environment. In addition, the common use of these chemicals in industry and consumer products has led to their widespread impact on the environment. The impact of these chemicals on your drinking water continues to be studied.

### **Why are PFAS being tested in my drinking water?**

In May 2019, Act 21 (S.49), an act relating to the regulation of per- and polyfluoroalkyl substances (PFAS) in drinking and surface waters, was signed by Governor Scott. This Act provides a comprehensive framework to identify PFAS contamination and to issue new rules to regulate PFAS levels in drinking water.

### **What if PFAS have been detected in my drinking water?**

Act 21 set an interim standard for the detected concentration of five PFAS in drinking water, or the combined concentration of any of the 5 PFAS, which should not exceed **20 parts per trillion (ppt)**. The interim standard is based on the Health Advisory established by the Vermont Department of Health. The five PFAS are:

- (PFNA):** Perfluorononanoic Acid
- (PFOA):** Perfluorooctanoic Acid
- (PFOS):** Perfluorooctane Sulfonic Acid
- (PFHpA):** Perfluoroheptanoic Acid
- (PFHxS):** Perfluorohexane Sulfonic Acid

If your water has been tested and the **sum any of the five PFAS listed above is confirmed to exceed 20 ppt**, a Do Not Drink notice will be issued informing you not to use your water for drinking or cooking, brushing teeth, making ice cubes, making baby formula, washing fruits and vegetables or any other consumptive use. You will be advised to use another source of water for consumption which may include bottled water.

An additional 13 PFAS were required to be tested for, per Act 21. These additional 13 PFAS, listed below, currently do not have an established health-based standard and are not counted toward the combined standard of 20 ppt:

- (11Cl-PF3OUdS):** 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid
- (9Cl-PF3ONS):** 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic Acid
- (DONA):** 4,8-Dioxa-3H-perfluorononanoic Acid
- (HFPO-DA):** Hexafluoropropylene Oxide Dimer Acid
- (NEtFOSAA):** N-ethyl perfluorooctanesulfonamidoacetic Acid
- (NMeFOSAA):** N-methyl perfluorooctanesulfonamidoacetic Acid
- (PFBS):** Perfluorobutane Sulfonic Acid
- (PFDA):** Perfluorodecanoic Acid
- (PFDoA):** Perfluorododecanoic Acid
- (PFHxA):** Perfluorohexanoic Acid
- (PFTA):** Perfluorotetradecanoic Acid
- (PFTrDA):** Perfluorotridecanoic Acid
- (PFUnA):** Perfluoroundecanoic Acid

**Where can I learn more about PFAS in drinking water?**

For information about the health effects of PFAS, please visit [www.healthvermont.gov/water/pfas](http://www.healthvermont.gov/water/pfas) or call the Vermont Department of Health at 1-800-439-8550. If you have specific health concerns, conta